

FORMER WOOD WOOLEN MILL SITE BOILER HOUSE

Interior Contents

Two coal-fired boilers (center and side)

Can see from north side of building on 1st Floor Level.

These boilers are very large (size unknown) and extend from basement to top level.

Both boilers are covered with asbestos insulation.

Face plate of these boilers was sampled (50% chrysotile)

Assumes 10-ft foot by 10-ft (100ft²) are also ACM.

Friable ACM from one of the boiler was removed and stored inside one of the boilers.

One “newer” oil fired “package” Boiler

Can see from south side of building on basement Level

One large Water Storage Tank

coated/wrapped/insulated with suspect ACM

Exterior Building Structure

- 100+ years old
- 40 feet by 50 feet foot print (2,000 ft²)
- multi-story structure – 3 stories (basement, first floor, second floor)
- each story 10 feet high (total height = ±30 feet)
- interior wood frame
- exterior wood (south and east faces) and brick (north and west faces)
- concrete slab in basement
- heated by steam
- no sprinkler system
- roof type (not specified – possibly wood or asphalt?)